

## **Stormwater Review for the Planning Board ESP01-1121**

### **12.06.21**

This plan is likely in a critical area due to slopes, working in the setbacks, and location and as such, according to Section H, will need a stormwater plan.

The Erosion and Sediment Control plans must meet the minimum standards of Appendix II.

In addition, this plan should address the Performance Standards in the 12.5.

### ***12.5 Performance Standards in the Aquifer Protection District***

All subdivision proposals and other proposed new developments within the Aquifer Protection District shall be reviewed by the Planning Board and shall conform to the provisions of this ordinance, the Subdivision Regulations of the Town of Wilton and the following:

- a. All such proposals are consistent with the need to protect the groundwater of the Town of Wilton and adjacent communities.
- b. All sanitary sewer systems are designed to minimize or eliminate leakage or discharges from the system into the groundwater.

*Unclear if this is a particular septic system that is specially designed in any way to minimize potential leakage.*

- c. On site waste disposal systems are located so as to avoid or minimize groundwater contamination.
- d. All surface storm water generated by development is kept on-site and handled in such a manner as to allow the water to infiltrate into the ground before leaving the site.

*There is no stormwater management evident on this plan.*

- e. Streets, roads, and parking areas are constructed so that the need for direct application of road salt is minimized for winter safety, and so that run-off from such uses is channeled to avoid or minimize groundwater contamination.

*There is no stormwater management shown. There is no snow storage shown, and it is unclear where the stormwater off the driveway will go.*

- f. Written approval of the State of New Hampshire Department of Environmental Services, Water Supply and Pollution Control Division for subdivision and septic systems has been obtained.
- g. Under the NH Groundwater Protection Act, existing uses or activities, within the WHPA, listed in [RSA 485-C](#) as Potential Contamination Sources (PCSs) shall follow Best Management Practices (BMPs) for Groundwater Protection as adopted under the NH

Code of Administrative Rules Part ENV-Ws 421, Best Management Practices. (*Adopted March, 2007*)

The plan should refer to the restricted uses or that if a use listed is proposed, that BMPs are followed.